

HSE Observation

Did you assist a co-worker today? Did you see an opportunity for improvement? Did you perform a stop and correct? Act

Observer's: Mark Bonneville *MB*

Name(s): Illo

Date: 2/10/05 Time: 1pm

Supervisor: Kevin McCarver

What did you observe? Act Condition

Please explain the act or condition that you observed.

got some #2 AWG copper single conductor from construction store and found a bare spot in the cable in about 30 ft in from the end. Had to cut about 3 ft off

Did you discuss your observation? Y N

Was it corrected? Y N

HSE Observation

Did you assist a co-worker today? Did you see an opportunity for improvement? Did you perform a stop and correct? Act

Observer's: Mark Bonneville *MB*

Name(s): Paul LeBlanc

Date: May 20/01 Time: 1pm

Supervisor: Kevin McCarver

What did you observe? Act Condition

Please explain the act or condition that you observed.

Conduits on wire cart could be a knee-banger, we could use 3 - 5/8" x 28" round stock material to make 3 new rods for cable reels to be inserted on, removing hazard all together. As part of this cart the rods are held in place with cotter hair pins, Rack is missing 10 pins in total.

Did you discuss your observation? Y N

Was it corrected? waiting for materials Y N